IAX/LUX/LEX SERIES

Low-Depth, Hydraulic-Magnetic Circuit Breakers

Introduction

Our lowest depth breaker family, the Airpax IAX/LUX/LEX series hydraulic magnetic circuit breaker allows increased density in datacenter rack power distribution units while leaving more space for equipment, wiring and airflow. These UL-489 Listed and IEC 60947-2 (pending) breakers are available in 1 and 2 pole models using a unique handle actuator (patent pending) which minimizes breaker volume while maintaining reliable switching and over current protection. Available high interrupt capacity 10 kAIC and low resistance all copper conductors meet the needs of high performing, high efficiency datacenters.



Features

- Based on the proven high performance of the Airpax LEG series
- Low depth to minimize PDU intrusion into equipment rack space
- 240VAC rating on a single pole further minimizes space requirements

Sensata

Technologies

- 5 kAIC and 10 kAIC versions available
- Standard (copper and brass) and low resistance (all copper) conductors available
- Unique handle actuator for protection against accidental "turn-off" with minimal size and no handle guard required
- Screw terminals provide secure vibration resistant connection for high reliability applications
- Terminal orientation allows simple power conductor routing and ease of assembly



SPECIFICATIONS

Percentage of Rated Current vs Trip Time in Seconds

Delay	100%	125 %	150%	200 %	400%	600 %	800%	1000%
61	No Trip	.7-12	.35-7	.130-3	.030-1	.0153	.0115	.011
62	No Trip	10-120	6-60	2-20	.2-3	.015-2	.0158	.01-25
63	No Trip	50-700	30-400	10-150	1.5-20	.015-10	.01385	.0135
69	No Trip	.120 MAX.	.100 MAX.	.050 MAX.	.022 MAX.	.017 MAX.	.017 MAX.	.017 MAX.

Typical Resistance / Impedance

Current Rating	DC Resistance - Ohms				
(Amps)	Standard	All Copper			
2.0	.400	.385			
14.0	.0098	.0091			
15.0	.0075	.0070			
20.0	.0049	.0046			
30.0	.0027	.0024			
DCR and Impedance based on 100% rated current applied and stabilized for a minimum of one hour. Tolerance 2.0 - 2.5 amperes ±					

stabilized for a minimum of one hour. Tolerance 2.0 - 2.5 amperes \pm 20%: 2.6 -20. amperes \pm 25%, 21.-30. amperes \pm 50%. Consult Sensata for special values and for coil impedance of delays not shown.

Inrush Pulse Tolerance

Delay	Pulse Tolerance			
61, 62, 63	10 times rated current (approx)			

The table above provides a comparison of inrush pulse tolerance for each of the 50/60Hz delays. Pulse tolerance is defined as a single pulse of half sine wave peak current amplitude of 8 milliseconds duration that will not trip the circuit breaker. Consult Sensata for further assistance.



www.sensata.com

Agency Approval - LUX Circuit Breakers

Max Voltage	Frequency (Hz)	Phase	Minimum Poles	UL/CSA rated current	UL489 short circuit
240	50/60	1	1	2-30	5,000
240	50/60	1	1 only	15-30	10,000
240	50/60	1	2 only	2-30	10,000



DELAY CURVES

50/60Hz Short Delay



50/60Hz Long Delay (Motor Start)



50/60Hz Medium Delay



50/60Hz 125% Instant Trip









Page 3

www.sensata.com



Example : LUXH A66-1-61-20.0-NR-01

Two Pole (One Handle per Pole), Two Pole, -1 Series, 50/60 Short Delay, 20 amps, "All Copper" Option/10kAIC, Black with White Markings

Г	LUXH – A	66 –	1 –	61 –	20.0 – N	R – ()1	
Туре			<u> </u>					
See following charts.								
Poles								
See following charts.								
Construction								
See following charts.								
Frequency & Delay								
See following charts.								
Amps								
See following charts.								
Miscellaneous								
See following charts.								
Marked (Combination On-Off	/ I-O)							
Cas fallouring shouts								

See following charts.

Туре

LUX	Single Pole	U.L. listed per 489, C22.2 No. 5	
LUXH	Two Pole One Handle per pole		
IAX	Single Pole	Special	
ІАХН	Two Pole One handle per pole	customer variation not covered by agency approvals.	

1. Individual units riveted together as a single unit are indicated by "M" following the "type" (e.g. LUXHM). Must be handles in all poles. No mechanical linkage is provided between units.

2. See ratings table for specific rating values

Construction

-1 Series

Amps

8.0	8 Amp
15.0	15 Amp
16.0	16 Amp
20.0	20 Amp
25.0	25 Amp
30.0	30 Amp

For other ratings, contact Sensata.

Poles

Screw Terminals	
Low Depth	
A6	Single Pole
A66	Two Pole

1. Screw terminals are 10-32. M5 terminals are available as an option in the sixth decision.

Frequency & Delay

-61	50/60 Short Delay	
-62	-62 50/60 Long Delay	
-63 50/60 Extra Long / Motor Start		
-69	50/60 125% Instant Trip	

Miscellaneous

-A	Metric thread mounting, terminals and screws
-N "All Copper" option	
-R	10kAIC

One or more descriptors may be used as required.
When no sixth decision is selected, ASME/ANSI threads will be supplied.

Marked (Combination On-Off / I-O)

-01	Black with White Markings
-----	---------------------------







• UL-489 Listed and IEC 60947-2 (pending)





RISK OF MATERIAL DAMAGE AND HOT ENCLOSURE

- The product's side panels may be hot, allow the product to cool before touching
- Follow proper mounting instructions including torque values
- Do not allow liquids or foreign objects to enter this product

Failure to follow these instructions can result in serious injury, or equipment damage.



HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Disconnect all power before installing or working with this equipment
- Verify all connections and replace all covers before turning on power
- Failure to follow these instructions can result in death or serious injury.

CONTACT US

electrical-protection-sales@

info-sse@list.sensata.com

China +86 (21) 2306 1500

Japan +81 (45) 277 7117

Korea +82 (31) 601 2004

India +91 (80) 67920890

+886 (2) 27602006 ext 2808

sales.isasia@list.sensata.com

Europe, Middle East & Africa

Americas

508-236-2551

sensata.com

+31743578156

Asia Pacific

Rest of Asia

Sensata Technologies, Inc. ("Sensata") data sheets are solely intended to assist designers ("Buyers") who are developing systems that incorporate Sensata products (also referred to herein as "components"). Buyer understands and agrees that Buyer remains responsible for using its independent analysis, evaluation and judgment in designing Buyer's systems and products. Sensata data sheets have been created using standard laboratory conditions and engineering practices. Sensata has not conducted any testing other than that specifically described in the published documentation for a particular data sheet. Sensata may make corrections, enhancements, improvements and other changes to its data sheets or components without notice.

Buyers are authorized to use Sensata data sheets with the Sensata component(s) identified in each particular data sheet. HOWEVER, NO OTHER LICENSE, EXPRESS OR IMPLIED, BY ESTOPPEL OR OTHERWISE TO ANY OTHER SENSATA INTELLECTUAL PROPERTY RIGHT, AND NO LICENSE TO ANY THIRD PARTY TECHNOLOGY OR INTELLECTUAL PROPERTY RIGHT, IS GRANTED HEREIN. SENSATA DATA SHEETS ARE PROVIDED "AS IS". SENSATA MAKES NO WARRANTIES OR REPRESENTATIONS WITH REGARD TO THE DATA SHEETS OR USE OF THE DATA SHEETS, EXPRESS, IMPLIED OR STATUTORY, INCLUDING ACCURACY OR COMPLETENESS. SENSATA DISCLAIMS ANY WARRANTY OF TITLE AND ANY IMPLIED WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, QUIET ENJOYMENT, QUIET POSSESSION, AND NON-INFRINGEMENT OF ANY THIRD PARTY INTELLECTUAL PROPERTY RIGHTS WITH REGARD TO SENSATA DATA SHEETS.

All products are sold subject to Sensata's terms and conditions of sale supplied at www.sensata.com SENSATA ASSUMES NO LIABILITY FOR APPLICATIONS ASSISTANCE OR THE DESIGN OF BUYERS' PRODUCTS. BUYER ACKNOWLEDGES AND AGREES THAT IT IS SOLELY RESPONSIBLE FOR COMPLIANCE WITH ALL LEGAL, REGULATORY AND SAFETY-RELATED REQUIREMENTS CONCERNING ITS PRODUCTS, AND ANY USE OF SENSATA COMPONENTS IN ITS APPLICATIONS, NOTWITHSTANDING ANY APPLICATIONS-RELATED INFORMATION OR SUPPORT THAT MAY BE PROVIDED BY SENSATA.

Mailing Address: Sensata Technologies, Inc., 529 Pleasant Street, Attleboro, MA 02703, USA.